



Gandhinagar Municipal Corporation

Pandit Dindayal Upadhyay Bhawan,
Behind Fire Station, Sector-11, Gandhinagar-382011,
Tel No.: (079) 232 84150 Fax No.: (079) 23221419,
Toll free Helpline no.1800 108 1818

Web site : <http://www.gandhinagarmunicipal.com> Email: gmc8gandhinagar@gmail.com

Outward: 12029

Date: 04/06/2025

Sanitary Certificate

I declare that I have inspected SHREE SARASWATI VIDHYALAYA, HIGHER SECONDARY, SSV CAMPUS, SECTOR 3/B, GANDHINAGAR-382006, GUJARAT INDIA school building and premises and certify that the school building is maintained neat and clean. The latrine arrangements are adequate and that in all other necessary aspect the sanitation is Satisfactory. However, in future, implementation will have to be done as per Sanitation and waste Management for school of Gandhinagar guideline.

Period: Jun 2025 to May 2026

Place: Gandhinagar

Assistant Director (Sanitation) (I/C)
Gandhinagar Municipal Corporation

(Ref: As per approval by Deputy Municipal Commissioner)

GUJARAT TESTLAB PRIVATE LIMITED

F-16,17,E-17 Madhavpura Market, Nr. Police Commissioner Office, Shahibaug, Ahmedabad-380004 (India)
Phone : 079-25626040, 25624821
email : gujlab@gmail.com, gujlab.info@gmail.com

TAX INVOICE

(Issued under sub-section(1) of section 31 of the CGST/SGST Act., 2017 read with Rule 46 of CGST Rules 2017)
Original for Recipient
Duplicate

Page 1 of 1

GSTIN Number: 24AAKCG3033E1Z1

Tax is Payable On Reverse Charge : No

PAN NO. AAKCG3033E

RN :UDYAM-GJ-01-0331154

Details of Receiver

M/S : Shree Saraswati Vidyalaya
Sector- 3B
City : Gandhinagar Pin Code : State :
Gujarat State Code :24
GSTIN/UIN :
PAN :
Phone : 9016102267

Ship To :

M/S : Shree Saraswati Vidyalaya
Sector- 3B
City : Gandhinagar Pin Code : State :
Gujarat State Code :24
GSTIN/UIN :
PAN :
Phone : 9016102267

Invoice No. : M 5395
Invoice Date : 02/08/2025
Place of Supply : Gujarat
PO No :

Sr. No.	Description of Service	Report No	SAC	Rate	Total Amount	Disc. %	Taxable Value	Total	
								Gross Amt	Tax Amt
1	Drinking Water N.M	GTL/03250728005	998346	1000.00	1000.00	0.00	1000.00	1000.00	180.00

BANK Details

ACCOUNT NO: 923020022458500 IFSC CODE : UTIB0000510
BANK NAME : AXIS BANK LTD. MICR CODE : 380211012
BRANCH : SHAHIBAUG, AHMEDABAD

CGST@ 9.00 90.00 Total Charges : 1000.00
SGST@ 9.00 90.00 Total Tax : 180.00
IGST@ 0.00 0.00 Round Off Amount : 0.00
Invoice Amount : 1180.00

Invoice Value (IN WORDS) : rupees one thousand one hundred eighty only

Certified that the Particulars given above are true and correct

- *The sample is accepted by us subject to our general conditions of services which is available on request
- *The testing has been performed to the best of our ability & total liability of our laboratory is limited to the invoice charges/testing charges only. the test certificate does not relieve the parties from their contractual obligations etc.
- *No complaints regarding this INVOICE will be entertained unless reported within 7 days
- *Payment requested by Cheque / D.D. / RTGS / NEFT in favour of "GUJARAT TESTLAB PRIVATE LIMITED" within 7 days.
- *All disputes are subject to ahmedabad Jurisdiction

For, GUJARAT TESTLAB PRIVATE LIMITED

Authorised Signatory



Report Issued To :	Shree Saraswati Vidyalaya Sector- 3B , Gandhinagar, Gujarat Phone No : 9016102267 Email : agtvs412@gmail.com	Test Report No : GTL/03250728005 Date of Receipt : 28/07/2025 Date of Issue : 31/07/2025 Customer's Ref. No : N.M
---------------------------	--	--

Sample Described as	: Drinking Water	Mfg. Date	: N.M.
Sample Qty	: 2.0 Ltr	Exp. Date	: N.M.
Packing Mode	: Sample Packed in Plastic Bottle	B.No	: N.M
Sample Condition	: Satisfactory		
Marking	: N.M		
Sample Drawn By	: Customer		
Date of Starting of Test	: 28/07/2025	Date of Completion	: 31/07/2025

Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
Chemical Water						
1	Colour, Hazen Unit	Max. 5	Max. 15.0	<1	1	IS:3025(P-4)
2	Odour	Agreeable	Agreeable	Agreeable	--	IS:3025(P-5)
3	pH at 25 Deg C	6.5 to 8.5	No Relaxation	7.35	1	IS:3025(P-11)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS:3025(P-7 & 8)
5	Turbidity, NTU	Max. 1.0	Max. 5.0	<0.1	0.1	IS:3025(P-10)
6	Total Dissolved Solids, mg/l	Max.500	Max.2000	1532	5	IS:3025(P-16)
7	Calcium (as Ca), mg/l	Max.75	Max.200	137.91	0.1	IS:3025(P-40)
8	Chloride (as Cl), mg/l	Max.250	Max. 1000	612.78	0.5	IS:3025(P-32)
9	Fluoride (as F) mg/l	Max. 1.0	Max. 1.5	B.L.Q.	0.01	IS:3025(P-75)
10	Magnesium (as Mg), mg/l	Max. 30	Max. 100	87.66	0.1	IS:3025(P-46)
11	Nitrate (as NO3) mg/l	Max. 45.0	No Relaxation	18.50	1	IS:3025(P-34)
12	Phenolic Compounds (as C6H5OH) mg/l	Max. 0.001	Max. 0.002	B.L.Q.	0.001	IS:3025(P-43) Sec 1
13	Sulphate (as SO4), mg/l	Max. 200	Max. 400	43.28	0.5	IS:3025(P-24 Sec-1)
14	Total Hardness (as CaCO3), mg/l	Max. 200	Max. 600	669.6	1	IS:3025(P-21)
Biological Water						
1	Total Coliform per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016

Test Report No : GTL/03250728005

Doc. No : GTL/D/7.5/02

Page 2 of 2


Sr No	Test Parameters	IS:10500 Requirement (Acceptable Limit)	IS:10500 Permissible Limit in the Absence of Alternate Source	Result	Quant. Limit	Test Method
2	E.coli per 100 ml	Shall not be Detectable	Shall not be Detectable	Absent	---	IS 15185 : 2016

Remark : Sample Found DOES NOT CONFORM as per is:10500-2012 with Amendment NO-4 for the tested parameter.

Note : N.M.=Not Mentioned, B.L.Q.=Below Limit of Quantification




For NABL Scope


Mamta Bhavsar
Reviewed By



For Verification

FOR, GUJARAT TESTLAB PVT. LTD

Rupesh Desai-Trupti Thakor
Autho. Signatory

*** END OF REPORT ***